

PARAMETRO	EXPRESIÓN	UNIDAD	RESULTADOS EFLUENTE BALLAST								Límite Máximo
			7/1/2009	s/fecha	3/9/2010	20/10/2010	s/fecha	19/11/2010	25/11/2010	31/12/2011	Permitido
PH	U	U	8.27	7.08	8.17		7	7.08	6.99	7.65	5.5-9.0
Temperatura	T	°C	3.3	0.8	3		29.7	28.3	31	25.9	3
Sólidos Suspendidos	SS	mg/L	23	21	<10	14	<1	6	12	10	35
Sólidos Totales, Disueltos	ST	mg/L	322	411	598	400	124	260	332	214	500
Turbiedad	NTU	NTU	18.4	7.57	6.04		1.07	8.1	6.75	7.52	30
Demanda Bioquímica de Oxígeno	DBO5	mg/L	8	45	15		2	47	13	10	35
Demanda Química de Oxígeno	DQO	mg/L	18	72	25.5		212	218	16	25	100
Relación DQO/DBO	DQO/DBO		2.25	1.6	1.7		106	4.6	1.2	2.5	
Aceites y Grasas	A Y G	mg/L	4	5	<5		<1	3	2	2	20
Conductividad	uS/cm	uS/cm	720	837	1045		1027	515.8	643	290	
Detergentes	Det.	mg/L	0.1	0.2	<0.2		0.31	0.41	0.55	0.21	1
Hidrocarburos Totales	THC	mg/L	0.5	5	<5		<0.05	<0.05	<0.05	<0.05	5
Coliformes Totales	C.T.	UFC/100mL	1200	4500	<100		10600	32000	28000	36000	1000
Cloruros	Cl	mg/L					68.6	52.1	77.7	28.8	400
Fósforo	P	mg/L					0.5	<0.05	<0.05	<0.05	5
Sulfuros	S-2	mg/L					0.65	<0.01	<0.01	<0.10	1
Compuestos Fenólicos	Fenoles	mg/L					<0.05	<0.05	<0.05	<0.05	0.5
Mercaptanos		mg/L					<0.05	<0.05	<0.05	<0.05	0.02