


ID	ITEM DESCRIPTION
1	LNG TRUCK LOADING SKID - (1) DUAL
2	TRUCK SCALE
3	TRUCK LOADING SUPPORT BUILDING (40 SQ.M.)
4	WASTE WATER SUMP
5	PARKING AREA
6	GUARD BOOTH FOR TRAFFIC CONTROL (3 SQ.M.)
7	SPILL IMPROVEMENT SUMP
8	FUTURE TRUCK SCALE
9	FUTURE TRUCK LOAD SKID
10	FIREWATER HOSE VALVES/MONITOR
11	TRANSFORMER
12	TRUCK LOADING CANOPY

LEGEND

	ZONE 1, GROUP 11 A, T4
	ZONE 2, GROUP 11 A, T4
	AREA NOT CLASSIFIED



NOTES

- ELECTRICAL AREA CLASSIFICATION IN ACCORDANCE WITH NFPA 497, NFPA 59A, AND API 505.
- FOR AREA CLASSIFICATION DETAILS, SEE DRAWING 242329-000-EL-10-000002.
- FOR LOADING/UNLOADING AREAS, A ZONE 1 AREA SHOULD EXIST WITHIN 1.5 METERS AND A ZONE 2 AREA WITHIN 4.6 METERS IN ALL DIRECTIONS FROM CONNECTIONS REGULARLY MADE OR DISCONNECTED FOR PRODUCT TRANSFER.
- DIMENSION TYPICAL FROM EDGE OF RACKS, BUILDINGS, AND WALLS.

REV	REVISION	DRAWN	CK'D	APPRO	DATE
2	AS BUILT	REU	FW		02NOV20
1	ISSUED FOR CONSTRUCTION	EMP	TAR	MW	04OCT19
0	ISSUED FOR CONSTRUCTION	EMP	TAR	MW	02AUG19
A	ISSUED FOR REVIEW	EMP	TAR	MW	15JUL19



Costa Norte LNG Terminal

**MODERMOTT**  
CB&I® STORAGE TANK SOLUTIONS

THIS DOCUMENT OR DRAWING IS THE SOLE PROPERTY AND COPYRIGHT OF MODERMOTT AND CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION. THIS DOCUMENT OR DRAWING CANNOT BE REPRODUCED, COPIED, RETAINED OR USED, IN WHOLE OR IN PART WITHOUT WRITTEN CONSENT OF MODERMOTT.

DRAWN: REU CK'D: FW APPD: DATE: 02NOV20 SCALE: AS SHOWN

HAZARDOUS AREA PLAN  
LNG TRUCK LOADING FACILITY  
COSTA NORTE LNG TRUCK LOADING ADDITION  
COLON, PANAMA

FOR:	AES CORPORATION	PROJECT NO:	242329
DWG NO:	242329-000-EL-10-000001	REV:	2