



BENTEL[®]
SECURITY

DECLARATION of CONFORMITY

The BENTEL SECURITY S.R.L. - Via Gabbiano, 22 - 64013 CORROPOLI (TE)

Declares that the product

J408-8

PFNCFBLEJ408-8
PFNCFBLEJ408-8NM
PFNCFBLIJ408-8
PFNCFBLSJ408-8

8Z.FIRE CONTROL PANEL J408-8 ENGLISH V.
8Z.FIRE C.PANEL J408-8/NM -NO LEXAN
8Z.FIRE CONTROL PANEL J408-8 ITALY VER.
8Z.CONV.F.PANEL ES

complies to the following standards:

Control and indicating equipment:	EN 54-2:1997+A1:2006
Power supply equipment:	EN 54-4:1997+A1:2002+A2:2006
Safety:	EN 60950-1:2006+A11:2009
Emission:	EN 61000-6-3:2007
Immunity:	EN 50130-4:1995+A1:1998+A2:2003

and thereby, complies the ESSENTIAL REQUISITES of DIRECTIVES

89/106/CEE
2006/95/CE
2004/108/CE

Notified Body:

IMQ S.p.A
Via Quintiliano, 43 - 20138 Milano
ITALIA

Corropoli (TE), 13/01/2010

CE 0051

**Il consigliere delegato
Andrea Cotichelli**

Certificato: 0051-CPD-0194